



Battalion Chief Thomas J. Pigott - Chief of Technology Management  
Office of Technology Management  
Bureau of Fire Prevention



9 METROTECH CENTER – BROOKLYN, NY 11201

## **TECHNOLOGY MANAGEMENT BULLETIN # 10-2/2009**

**To: Public Agencies, Real Estate Entities, Architects, Engineers, Fire Alarm and Construction Industry Entities, Fire Safety Directors and Building Managers**

**Re: Clarification of Fire Department and Department of Buildings Consultative Determination regarding replacement of control equipment and/or Fire Command Stations of existing prior approved Advisory Class 'E' fire alarm systems or new replacements of entire systems of the Advisory Class E fire alarm systems.**

- 1. After consultation between the NYC Department of Buildings Technical Affairs and the NYC Fire Department Office of Technology Management the policy is hereby enacted, in the interest of life safety, that any Advisory Class 'E' fire alarm system, which is either not functional and/or requires replacement of the Fire Command Station, shall be upgraded to a Modified Class 'E' system under the auspices of the 1968 Building code, if applicable, or in accordance with the 2008 Building Code upgraded to the High Rise code provisions of BC § 907.2.12 as applicable to new and/or existing building construction installation regulations.**



Battalion Chief Thomas J. Pigott - Chief of Technology Management  
Office of Technology Management  
Bureau of Fire Prevention



9 METROTECH CENTER – BROOKLYN, NY 11201

**TECHNOLOGY MANAGEMENT BULLETIN # 10-2/2009**

(Continued)

**To: Public Agencies, Real Estate Entities, Architects, Engineers, Fire Alarm and Construction Industry Entities, Fire Safety Directors and Building Managers**

**Re: Clarification of Fire Department and Department of Buildings Consultative Determination regarding replacement of control equipment and/or Fire Command Stations of existing prior approved Advisory Class 'E' fire alarm systems or new replacements of entire systems of the Advisory Class E fire alarm systems**

2. It is agreed that in accordance with the above policy the Bureau of Fire Prevention shall reject submitted applications of new fire alarm installations of Advisory Class 'E' fire alarm systems with the exception of minor repairs, replacement and/or additions of notification and initiating fire alarm appliances and devices. The replacement of critical control panels and equipment shall be governed by the foregoing paragraph #1.

The above declarations of the public safety policies of the Bureau of Fire Prevention have been made to clarify officially the impact of the city of New York interagency cooperation between the NYC Department of Buildings and the NYC Fire Department for the administration of the Office of Technology Management activities concerning fire alarm issues and its affects upon the real estate, buildings design and construction industries.

Signed,

Thomas Jensen  
Chief of Fire Prevention