



## NASSAU COUNTY FIRE COMMISSION OFFICE OF THE FIRE MARSHAL

Nassau County Public Safety Center  
1194 Prospect Avenue  
Westbury, New York 11590  
(516) 573-9900 / [nassaucountyny.gov](mailto:nassaucountyny.gov)

Chief Fire Marshal

# FIRE MARSHAL BULLETIN

February 14, 2017

To: NYS Licensed Alarm Contractors and all NCFM Licensed Fire Protection Contractors submitting Design Drawings

From: Assistant Chief Fire Marshal Michael F. Uttaro [muttaro@nassaucountyny.gov](mailto:muttaro@nassaucountyny.gov)

The recently approved Nassau County Fire Prevention Ordinance, Article XXIV, sets forth the minimum requirements for design drawings for the following systems:

- Flammable & Combustible Liquids
- Application of Flammable Finishes
- Liquefied Petroleum Gas (Propane)
- Fire Alarm System
- Fire Sprinkler System
- Standpipe and Hose System
- Grease Hood and Duct System
- Automatic Fire Extinguishing System
- Alternative Automatic Fire Extinguishing System (Clean Agent Fire System)
- Pyrotechnics
- Special Systems

Included in these requirements is the adoption of NFPA 170, Standard for Fire Safety & Emergency Symbols.

In an effort to standardize design drawings submitted to the Nassau County Fire Marshal, all design drawings shall utilize the appropriate symbols specified in **NFPA 170- 2015**, effective **May 1, 2017**.

Any design drawings submitted on or after **May 1, 2017** that do not conform to the symbols in NFPA 170-2015 will be rejected.